

SAFETY AND BUILDINGS DIVISION Plumbing Product Review P.O. Box 2658 Madison, Wisconsin 53701-2658

Jim Doyle, Governor Mary P. Burke, Secretary

March 25, 2004

BIO-SYSTEMS INTERNATIONAL MALCOLM PEACOCK 1238 E. TRUMAN PARKWAY BELOIT WI 53511

Re: Description: CHEMICAL OR BIOCHEMICAL SEPTIC TANK ADDITIVE

Manufacturer: BIO-SYSTEMS INTERNATIONAL

Product Name: L1020 Model Number(s): NONE Product File No: 20030547

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2009.

This approval is contingent upon compliance with the following stipulation(s):

- If the formulation of this approved septic tank additive is modified, or additional assertions of function or performance are made, then this approval shall be rendered null and void, unless the change is submitted to this department for review and the approval reaffirmed.
- This product does not replace the need for a regular program of inspection and maintenance. This includes having the tank pumped out when the volume of sludge and/or scum occupies one-third of the tanks liquid capacity.

Based on information supplied by the manufacturer and reviewed by the department, this approval recognizes that this plumbing product will not adversely affect bacterial action in the private sewage system, soil hydraulic conductivity in the absorption areas, or groundwater quality beneath the system when used in accordance with the manufacturer's instructions.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

SBD-10564-E (N.10/97) File Ref: 03054701.DOC

BIO-SYSTEMS INTERNATIONAL Page 2 March 25, 2004

Sincerely,

Glen W. Schlueter
Engineering Consultant-Plumbing Product Reviewer
Bureau of Integrated Services
Safety and Buildings Division
Department of Commerce
(608) 267-1401 Phone
(608) 267-9566 Fax
gschlueter@commerce.state.wi.us Email

GWS:gws